

DISTRICT WATER TESTING LABORATORY, BARNALA

Court Complex Barnala, Near Suvidha Kendra, Old Water Supply Scheme, Barnala
dwtlbarnala@gmail.com



TC-18624

TEST REPORT

Name & Address of Customer : Young Scholars School (Affiliated to CBSE), Barnala		Customer Reference No.	No : 710 Dated : 16/05/2025
		Sample Submitted by	Kulwinder Singh (J.E)
		Date of Sample Receipt	19/05/2025
		Analysis Starting Date	19/05/2025
		Analysis completion Date	20/05/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC15524250000028F	Sample Type :	Treated Water
Test Report No.:	DWTL/BAR/2526/00030	Date of Issue :	21/05/2025
Registration no.:	DWTL/BAR/REG2526/00143	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Young Scholars School (Affiliated to CBSE), Barnala / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Barnala	District :	Barnala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.18@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	98	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	54	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	42	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	12	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	7	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	17	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

President/Secretary
Young Scholars Edu. Society
BARNALA

Principal
YS SCHOOL
Sanghvi Bypass Road, Barnala

Reviewed and Approved By

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For District Water Testing Laboratory
Barnala

End of the Test Report